



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 1-017432
Permit # 01462-2009UPG
Request Rec'd 11/10/2009
Amended Date
Approval Date 11/18/2009 DS
Permit Expires 5/18/2010

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>IL Department Of Corrivyiond Sheridan        4017 East 2603 Road, P. O. Box 38        Sheridan, IL 60551</p> <p>Contact: Greg Hitchins (815) 496-2181</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Sheridan Correctional Center        4017 EAST 2603 ROAD        Sheridan, LaSalle Co., IL</p> <p>Contact: Greg Hitchins (815) 496-2181</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 20) - 2,500 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:**
- (d) **Product to be stored in each tank:** (TK # 20) - Diesel Fuel
- (e) **Type of leak detection being used:**  
     **Tank:** (TK # 20) - (Installing) Hydrostatic Reservoir Sensors Interstitial Monitoring Veeder Root TLS 350  
     **Piping:** (TK # 20) - (Installing) Mechanical Pressurized Line Leak Detection Red Jacket FX1DV
- (f) **Corrosion Protection being used:**  
     **Tank:**  
     **Piping:**
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>Contact Person:          Phone:          Contractor Registration #    Exp.</p>
--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)