



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 2-001258
 Permit # 00288-2013UPG
 Request Rec'd 04/11/2013
 Amended Date
 Approval Date 4/11/2013 JC
 Permit Expires 10/11/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Standard Bank Land Trust #16633 41 Horseshoe Lane, Chetty Sevugan - Beneficiary Lemont, IL 60439 Contact:</p>	<p>(2) FACILITY - name and address where tanks are located: Woodstock Petroleum, Inc. 11501 South Harlem Avenue Worth, Cook Co., IL Contact: Kamran (708) 671-1791</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 6) - 15,000 gallons, (TK # 7) - 8,000 gallons, (TK # 8) - 7,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 6, 7, 8) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/L to replace all existing piping from all submersibles to all dispensers. Contractor states there are existing submersible sumps, existing dispenser sumps, existing line leak detectors, and existing interstitial piping sump sensors at all submersible sumps and at all dispenser sumps.
- (d) *Product to be stored in each tank:* (TK # 6, 7) - Gasoline, (TK # 8) - Diesel Fuel
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Ancona, IL 61311</p>	<p>Contact Person: Randy Finck Phone: (815) 712-3245 Contractor Registration # Exp.</p>
--	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 9/10)