



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605
Amended

FOR OFFICE USE ONLY
Facility # 2-044532
Permit # 01042-2009ABN
Request Rec'd 08/17/2009
Amended Date 10/01/2009
Approval Date 8/25/2009 DS
Permit Expires 2/25/2010

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: 603-635 Rogers, LLC, York Second 603 Rogers Street Downers Grove, IL 60575 Contact:	(2) FACILITY - name and address where tanks are located: Multi-Tenant Commercial Building 136 York Street Elmhurst, Du Page Co., IL Contact:
---	---

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) *Number and size tanks being abandoned:* (TK # 1) - 350 gallons
- (b) *Location of tanks being abandoned:* Tank is located under floor slab with load bearing walls in close proximity to tank with no safe access for removal.

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) **SPECIAL CONTINGENCIES:** The waiver request by a licensed structural engineer, to allow a sewer to pass through this 350 abandoned heating oil tank is granted, provided the tank is filled with concrete slurry and a 6" cast iron sleeve is installed in the tank as directed by the structural engineer.
- (6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> R. W. Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Ann H Collins Phone: (708) 458-6868 Contractor Registration # Exp.
---	---

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)