



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Extended

FOR OFFICE USE ONLY
Facility # 2-020248
Permit # 01101-2012UPG
Request Rec'd 10/16/2012
Amended Date
Approval Date 10/16/2012 DS
Permit Expires 10/16/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: DOT/FAA Chicago ARTCC District 619 Indian Trail Road Aurora, IL 60506 Contact: Keith Brandt (708) 906-8251	(2) FACILITY - name and address where tanks are located: DOT/FAA Chicago ARTCC (ZAU ARTCC) 619 Indian Trail Road Aurora, Kane Co., IL Contact: Bernard Healy (312) 897-2061
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 6, 7, 8) - 10,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 6, 7, 8) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC generator supply and return lines, (TK # 6, 7, 8) - (Installing) Fiberglass Single Wall Piping A.O. Smith, (TK # 6, 7, 8) - (Installing) Chase Secondary Containment A.P.T. Poly Tech DCT-400 to contain primary and return lines

(d) Product to be stored in each tank: (TK # 6, 7, 8) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 6, 7, 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all new submersible sumps and at the new transition sump that will be installed per site plan, (TK # 6, 7, 8) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 6, 7, 8) - (Installing) Fiberglass Non-Corrosive, (TK # 6, 7, 8) - (Installing) Flexible Non-Corrosive

(g) Spill containment devices, piping, and dispenser containment devices: (TK # 6, 7, 8) - (Installing) Manhole Pre-manufactured OPW 1C-2115 DEVR spill containment manhole

(h) Overfill prevention devices: (TK # 6, 7, 8) - (Installing) Overfill Drop Tube Valve OPW 71SO

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Lansing, IL 60438	Contact Person: Ed Angell Phone: (708) 474-3344 Contractor Registration # Exp.
--	--

Sincerely,

Daniel Starks