



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY  
Facility # 2-010685  
Permit # 00277-2013UPG  
Request Rec'd 04/09/2013  
Amended Date  
Approval Date 4/10/2013 JC  
Permit Expires 10/10/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Graham C-Stores Company 33978 N. US Hwy 45, Gages Lake, IL 60030-0089  Contact: Mike Graham (847) 223-3710	<b>(2) FACILITY</b> - name and address where tanks are located:  Lake Zurich Phillips 66 1 North Rand Rand Lake Zurich, Lake Co., IL  Contact: Mike Graham (847) 223-3710
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired:* (TK # 1) - 8,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 1) - (Installing) Shear Valve at dispenser sump #1/2 only, to replace the existing defective shear valve. Contractor states there is an existing sump.
- (d) Product to be stored in each tank:* (TK # 1) - Gasoline
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Chicago Heights, IL 60411	Contact Person: Ray Kirchner Phone: (708) 758-3222 Ext. 12  Contractor Registration # IL-194 Exp.
--	--

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 9/10)