



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 1-039114
Permit # 01080-2009UPG
Request Rec'd 08/20/2009
Amended Date
Approval Date 8/31/2009 DS
Permit Expires 2/28/2010

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Flying J, Inc.          333 West Center Street          North Salt Lake, UT 84054          Contact: Hayden Sampson</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Flying J South Beloit          16049 Willowbrook Road          South Beloit, Winnebago Co., IL          Contact: Deloy Johnson (801) 334-4754</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1, 2, 3) - 20,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 1, 2, 3) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX to supply new blending shed, piping will also leave shed and transition into existing Environ via transition sumps.
- (d) **Product to be stored in each tank:** (TK # 1, 2, 3) - Diesel Fuel
- (e) **Type of leak detection being used:**  
  - Tank:**
  - Piping:** (TK # 1, 2, 3) - (Installing) Mechanical Pressurized Line Leak Detection Vaporless LD 3000 , (TK # 1, 2, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Omntec BX-LS in all new transition sumps, as well as in the entry and exit sumps being installed under blending shed
- (f) **Corrosion Protection being used:**  
  - Tank:**
  - Piping:**
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p align="right">Contact Person:          Phone:          Contractor Registration #    Exp.</p>
--

Sincerely,

Daniel Starks

