



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 4-031871
Permit # 00244-2013UPG
Request Rec'd 03/28/2013
Amended Date
Approval Date 3/28/2013 JC
Permit Expires 9/28/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Martin & Bayley, Inc. 1311 A. W. Main Street Carmi, IL 62821 Contact: Troy Deitz (618) 382-2334	(2) FACILITY - name and address where tanks are located: Hucks #186 701 Cleveland Street Heyworth, McLean Co., IL Contact: Mark Bayley (309) 473-2023
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 4) - 15,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 4) - (Installing) Chase Secondary Containment A.P.T. from the tank to the existing three diesel dispensers and to the new diesel dispenser, (TK # 4) - (Installing) Dispenser Sumps containment FRP for the three existing diesel dispensers and for the new diesel dispenser, (TK # 4) - (Installing) Submersible Sumps containment FRP for both of the submersible pumps for this tank, (TK # 4) - (Installing) Flexible Double Wall A.P.T. Poly Tech P200SC product piping from the tank to the existing three diesel dispensers **(replacing all existing piping from the tank to the three existing dispensers)**, and to the new diesel dispenser. The piping will be manifolded just outside of the two submersible pumps for this tank.

(d) Product to be stored in each tank: (TK # 4) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 4) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at each submersible sump for this tank, and at the three existing diesel dispenser sumps and at the new diesel dispenser sump. Contractor states there is an existing MLLD.

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 4) - (Installing) Fiberglass Non-Corrosive secondary chase piping, (TK # 4) - (Installing) Flexible Non-Corrosive primary product piping.

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Pekin, IL 61554	Contact Person: Pete Bradshaw Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp.
--	--

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)