



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 3-032390
 Permit # 00243-2013UPG
 Request Rec'd 03/28/2013
 Amended Date
 Approval Date 3/28/2013 JC
 Permit Expires 9/28/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Conway Central Express 4880 Venture Drive Ann Arbor, MI 48108</p> <p>Contact: Stone Nick (313) 994-6600</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Conway Central Express 4300 81st Avenue West Rock Island, Rock Island Co., IL</p> <p>Contact: John Pickens (309) 787-9662</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1) - (Installing) Dispenser Sumps containment FRP at the existing island only, (TK # 1) - (Installing) Submersible Sumps containment FRP at the submersible pump only, to replace the existing submersible sump, (TK # 1) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC from the submersible pump to the existing island only, to replace the existing piping.
- (d) *Product to be stored in each tank:* (TK # 1) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 1) - (Installing) Piping Sump Sensors Interstitial Monitoring EBW LS-3A at the dispenser sump only. Contractor states there is an existing sensor at the submersible sump.
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 1) - (Installing) Flexible Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Moline, IL 61265</p>	<p>Contact Person: Rob Vyncke Phone: (309) 762-1729</p> <p>Contractor Registration # Exp.</p>
--	--

Sincerely,

Jim Coffey

