



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605
PIPING ONLY

FOR OFFICE USE ONLY
Facility # 5-008900
Permit # 00798-2009REM
Request Rec'd 07/07/2009
Amended Date
Approval Date 7/7/2009 DS
Permit Expires 1/7/2010

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Mike Blasa 406 W. Carpenter Street Jerseyville, IL 62052 Contact:	(2) FACILITY - name and address where tanks are located: 16 W. Quik Shop 406 W. Carpenter Street Jerseyville, Jersey Co., IL Contact: Paul Phelan (618) 498-6932
---	---

(3) REMOVAL OF TANKS:

- (a) **Number and size of tanks being removed:** (TK # 1, 2) - 8,000 gallons, (TK # 3) - 6,000 gallons, (TK # 4) - 1,000 gallons, (TK # 5) - 550 gallons
 - (b) **Product stored in each tank:** (TK # 1, 3) - Gasoline, (TK # 2, 5) - Diesel Fuel, (TK # 4) - Kerosene
 - (c) **Reason of tanks being removed:** Contractor removing piping only!!!
 - (d) **If tank(s) is leaking, indicate IEMA incident number:**
 - (e) **Date each tank was last used:** (TK # 1) - 03/01/1988, (TK # 2), (TK # 3), (TK # 4), (TK # 5)
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES:** Original permit application was submitted as an Upgrade, however there needs to be a site assessment done after the removal of piping, therefore this is being issued as a Removal permit. Contractor is removing existing piping that supplied a previously removed dispenser island that was removed and the piping was capped. The piping being removed is thought to "tee" from existing piping that still supplies the current dispenser island, but the Contractor is unaware which tanks supplied the removed island and will only know once the concrete is broken and the lines excavated. STSS to field verify which tanks supply these lines.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
R. L. Hoener Company	Contact Person:
	Phone:
	Contractor Registration # Exp.

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 6/07)