



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-042924
Permit # 00226-2013REM
Request Rec'd 03/22/2013
Amended Date
Approval Date 3/25/2013 JC
Permit Expires 9/25/2013

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Kaloco 5, Inc. P.O. Box 1027 Morton Grove, IL 60053-1027 Contact: Nick Gianaris	(2) FACILITY - name and address where tanks are located: Zion Shell 4551 IL Rt. 173 Zion, Lake Co., IL Contact: Mohinder Singh (847) 293-3122
---	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 1) - 20,000 gallons, (TK # 3) - 6,000 gallons, (TK # 5) - 10,000 gallons
- (b) *Description/location of piping being removed:* ***All three tanks will be removed; however, only the local area of piping within the tank field will be removed (see the contingencies section)***
- (c) *Product stored in each tank:* (TK # 1, 3, 5) - Water
- (d) *Reason of tanks being removed:* ***Installation of new tanks.***
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used:* (TK # 1), (TK # 3), (TK # 5)
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES:** **These tanks never contained any product; therefore, these tanks were never registered (contractor cover letter states these tanks / facility did not pass the final inspection). Water is the only thing these tanks contained according to our records. The majority of the piping will remain - Permit #00225-2013INS is for the installation of tanks 7,8,9 (these new tanks will hook into the existing piping - contingent upon 175.420(b)).**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Interstate Pump & Tank, Inc. 901 Niagara Street Waukesha, WI 53186	Contact Person: Phone: Contractor Registration # Exp.
---	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)