



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-022701  
Permit # 00642-2009REM  
Request Rec'd 06/04/2009  
Amended Date  
Approval Date 6/4/2009 DS  
Permit Expires 12/4/2009

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Amoco Research Center (F-3/EHS) 150 West Warrenville Road Naperville, IL 60563 Contact: James L Saylor (630) 420-4874	<b>(2) FACILITY</b> - name and address where tanks are located: BP Naperville Campus 150 West Warrenville Road, P.O. Box 3011 Naperville, Du Page Co., IL Contact: James Saylor (630) 420-4874
---	--

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed:* (TK # 48, 49) - 20,000 gallons, (TK # 75, 76, 77, 78, 79) - 2,000 gallons
- (b) *Product stored in each tank:* (TK # 48, 75, 76, 78) - Diesel Fuel, (TK # 49, 77, 79) - Gasoline
- (c) *Reason of tanks being removed:*
- (d) *If tank(s) is leaking, indicate IEMA incident number:*
- (e) *Date each tank was last used:* (TK # 48, 49, 75, 76, 77, 78, 79) - 08/07/2008

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b> ABD Tank & Pump Company, Inc. 730 Industrial Drive Elmhurst, IL 60126	Contact Person: Jim Veverka Phone: (630) 530-9880 Contractor Registration #    Exp.
--	---

Sincerely,



cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 6/07)