



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

FOR OFFICE USE ONLY  
 Facility # 2-009692  
 Permit # 01276-2012UPG  
 Request Rec'd 12/04/2012  
**Amended Date 03/21/2013**  
 Approval Date 12/6/2012 JC  
 Permit Expires 6/6/2013

## Amended

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Delta Sonic Car Wash System, Inc.          570 Delaware Avenue          Buffalo, NY 14202          Contact: Bruce A Natalizia (716) 878-9388</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Crestwood Car Wash Systems          13740 South Cicero Avenue          Crestwood, Cook Co., IL          Contact: Rusick Janet (708) 448-5749</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 4) - 18,000 gallons, (TK # 5) - 7,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 4, 5) - (Installing) 4" Chase Secondary Containment from the tanks to the new island dispensers from permit #01275-2012INS (see related site plans), (TK # 4, 5) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC from the tanks to the new island dispensers from permit #01275-2012INS (see related site plans). **Contractor will be re-using the existing line leak detectors and the existing submersible sump sensors. See contingencies section.**, (TK # 4, 5) - (Installing) **Submersible Sumps containment FRP**
- (d) **Product to be stored in each tank:** (TK # 4, 5) - Gasoline
- (e) **Type of leak detection being used:**  
 Tank:  
 Piping:
- (f) **Corrosion Protection being used:**  
 Tank:  
 Piping: (TK # 4, 5) - (Installing) Fiberglass Non-Corrosive secondary chase piping, (TK # 4, 5) - (Installing) Flexible Non-Corrosive primary product piping.
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>           Chicago Heights, IL 60411</p>	<p>Contact Person: Douglas Harmon          Phone: (708) 758-3222 Ext. 12          Contractor Registration # Exp.</p>
--	--

Sincerely,

Jim Coffey

