



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 6-044324
Permit # 00521-2009INS
Request Rec'd 04/15/2009
Amended Date
Approval Date 5/5/2009 DS
Permit Expires 11/5/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Love's Travel Stops & Country Stores, Inc. P.O. Box 26210 Oklahoma City, OK 73126 Contact: Michael Key (405) 302-6640	(2) FACILITY - name and address where tanks are located: Love's Travel Stop #384 1900 S. State Route 127 Greenville, Bond Co., IL Contact:
---	---

(3) INSTALLATION OF TANKS:

(a) Number and size of tanks being installed: (TK # 1, 2, 3, 4, 5) - 20,000 gallons, (TK # 6) - 12,000 gallons, (TK # 7) - 8,000 gallons

(b) Type of tanks: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Fiberglass Double Wall XERXES

(c) Type of piping: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX (see contingencies for siphon piping information)

(d) Product to be stored in each tank: (TK # 1) - B-99, (TK # 2, 3, 4) - Diesel Fuel, (TK # 5, 6, 7) - Gasoline

(e) Type of leak detection being used:

Tank: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 , (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Interstitial Monitoring Veeder Root TLS 350

Piping: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in ALL sumps (see contingencies) , (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350

(f) Corrosion Protection being used:

Tank: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Fiberglass Non-Corrosive

Piping: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Fiberglass Non-Corrosive

(g) Spill containment devices: (TK # 1, 5, 6, 7) - (Installing) Manhole Pre-manufactured EBW 400 CS , (TK # 2, 3, 4) - (Installing) Field Constructed

(h) Overfill prevention devices: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Overfill Alarm Veeder Root TLS 350

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp. 02/09/2010

Sincerely,

