



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-024488  
Permit # 00381-2009INS  
Request Rec'd 03/18/2009  
Amended Date  
Approval Date 4/9/2009 DS  
Permit Expires 10/9/2009

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  MKM Oil, Inc. P.O. Box 317 Gardner, IL 60424  Contact: Rick Marketti (815) 237-0100	<b>(2) FACILITY</b> - name and address where tanks are located:  Mazon Shell Fast N Fresh 603 East Street Mazon, Grundy Co., IL  Contact: William H Whitmore (815) 476-5777
--	---

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:** (TK # 4) - 20,000 gallons
- (b) Type of tanks:** (TK # 4) - (Installing) Fiberglass Double Wall Containment Solutions
- (c) Type of piping:** (TK # 4) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC Product Piping, (TK # 4) - (Installing) Fiberglass Single Wall Vent Piping Ameron
- (d) Product to be stored in each tank:** (TK # 4) - Gasoline
- (e) Type of leak detection being used:**
  - Tank:** (TK # 4) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 with CSLD , (TK # 4) - (Installing) Interstitial Monitoring Veeder Root TLS 350
  - Piping:** (TK # 4) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350 , (TK # 4) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all dispenser and submersible sumps
- (f) Corrosion Protection being used:**
  - Tank:** (TK # 4) - (Installing) Fiberglass Non-Corrosive
  - Piping:** (TK # 4) - (Installing) Non-Corrosive Flexible Non-Corrosive
- (g) Spill containment devices:** (TK # 4) - (Installing) Manhole Pre-manufactured EBW 705
- (h) Overfill prevention devices:** (TK # 4) - (Installing) Overfill Drop Tube Valve Emco Wheaton A1100 Guardian

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

<b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>          Contact Person: Phone: (309) 694-8223  Contractor Registration # IL-1079 Exp. 02/08/2010
---

Sincerely,



cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)