

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services 1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

# Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE

MIROVAL DATE.	
(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
AMDOCS 2301 Fox Drive Champaign, IL 61820	AMDOCS 2301 Fox Drive Champaign, Champaign Co., IL
Contact: Newt Dodds (217) 356-1448	Contact: Newt Dodds (217) 356-1448

### (3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) 10,000 gallons
- (b) Type of tanks:
- (c) *Type of piping:* (TK # 1) (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX supply and return line to fuel existing generators
- (d) Product to be stored in each tank: (TK # 1) Diesel Fuel
- (e) Type of leak detection being used:

Tank:

Piping: (TK # 1) - (Installing) European with No Test Req Suction

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 1) - (Installing) Fiberglass Non-Corrosive

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.state.il.us/osfm</u> or by calling (217)785-1020.

Daniel Starks

### (5) <u>SPECIAL CONTINGENCIES</u>:

### (6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Chris Epkins Phone: (309) 347-1819

Contractor Registration # IL-1293 Exp.

Sincerely,

Daniel J. Starke

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)