

## Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE

THIS FERMIT IS VALID FOR SIX MONTHS FROM THE ATTROVAL DATE.	
(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Road Ranger, LLC 4930 East State Street, P.O. Box 4745 Rockford, IL 61110-4745	Road Ranger #210 890 East Highway 38 Rochelle, Ogle Co., IL
Contact: John Carabelli	Contact: Richard McMahon (815) 961-1700

## (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 5) 20,000 gallons
- (b) Type of tanks: (TK # 5) (Installing) Fiberglass Double Wall XERXES
- (c) Type of piping: (TK # 5) (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX
- (d) Product to be stored in each tank: (TK # 5) B-99
- (e) Type of leak detection being used:

*Tank:* (TK # 5) - (Installing) Interstitial Monitoring Veeder Root TLS 350 in conjunction with existing TLS 350 tank monitoring system

*Piping:* (TK # 5) - (Installing) European with No Test Req Suction, (TK # 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in new tank sump as well as in new injection sump

#### (f) Corrosion Protection being used:

Tank: (TK # 5) - (Installing) Fiberglass Non-Corrosive

Piping: (TK # 5) - (Installing) Fiberglass Non-Corrosive

- (g) Spill containment devices: (TK # 5) (Installing) Manhole Pre-manufactured OPW 1
- (h) Overfill prevention devices: (TK # 5) (Installing) Overfill Drop Tube Valve OPW 61SO
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.state.il.us/osfm</u> or by calling (217)785-1020.

#### (5) GENERAL REQUIREMENTS:

## (6) <u>SPECIAL CONTINGENCIES</u>:

# (7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Phone: (309) 347-1819

Contractor Registration # IL-1293 Exp. 02/09/2010

Sincerely,

Daniel J. Starke

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)