

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 2-009105
Permit # 00313-2009INS
Request Rec'd 03/23/2009
Amended Date
Approval Date 3/23/2009
DS
Permit Expires 9/23/2009

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
B.A.P.A., LLC & PT, LLC. S&S Petroleum 31366 North Highway 45, DBA/ State Oil Company Libertyville, IL 60048	State Oil Co. #212 Rolling Meadows Marathon 3321 Algonquin Road Rolling Meadows, Cook Co., IL
Contact: Jim E Peters (847) 680-5831	Contact: Jim Peters (847) 680-5831

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 9, 10, 11) 12,000 gallons
- (b) Type of tanks: (TK # 9, 10, 11) (Installing) Fiberglass Double Wall XERXES
- (c) Type of piping: (TK # 9, 10, 11) (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX
- (d) Product to be stored in each tank: (TK # 9, 10) Gasoline, (TK # 11) Diesel Fuel
- (e) Type of leak detection being used:
 - *Tank:* (TK # 9, 10, 11) (Installing) Automatic Tank Gauging Veeder Root TLS 350 with CSLD, (TK # 9, 10, 11) (Installing) Interstitial Monitoring Veeder Root TLS 350
 - *Piping:* (TK # 9, 10, 11) (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in alld ispenser sumps and in all submersible sumps, (TK # 9, 10, 11) (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) Corrosion Protection being used:

Tank: (TK # 9, 10, 11) - (Installing) Fiberglass Non-Corrosive

Piping: (TK # 9, 10, 11) - (Installing) Fiberglass Non-Corrosive

- (g) Spill containment devices: (TK # 9, 10, 11) (Installing) Manhole Pre-manufactured OPW 1-2100
- (h) Overfill prevention devices: (TK # 9, 10, 11) (Installing) Overfill Drop Tube Valve OPW 61SO, (TK # 9, 10, 11) (Installing) Overfill Alarm Veeder Root TLS 350, (TK # 9, 10, 11) (Installing) Ball Float Vent Valve OPW 53
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

(7)	PERSON,	FIRM OR	COMPANY	PERFORMING	WORK:
------------	---------	---------	---------	------------	-------

Contact Person:

Daniel J. Starke

Phone: (815) 398-6250

Contractor Registration # IL-1890 Exp. 03/07/2010

Sincerely,

cc: Storage Tank Safety Specialist - Fire Department -

Office Coordinator -Division File

(Rev. - 1/98)