



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 1-015010  
Permit # 00249-2009INS  
Request Rec'd 03/11/2009  
Amended Date  
Approval Date 3/11/2009 DS  
Permit Expires 9/11/2009

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104 Contact: John Griffin	<b>(2) FACILITY</b> - name and address where tanks are located: KW Truck Stop 1130 Harrison Avenue Rockford, Winnebago Co., IL Contact: Griffin John C (815) 397-9410
---	---

**(3) INSTALLATION OF TANKS:**

- (a) **Number and size of tanks being installed:** (TK # 5, 6) - 10,000 gallons, (TK # 7, 8) - 8,000 gallons
  - (b) **Type of tanks:** (TK # 5, 6, 7, 8) - (Installing) Fiberglass Double Wall XERXES
  - (c) **Type of piping:** (TK # 5, 6, 7, 8) - (Installing) Partial Fiberglass Double Wall Ameron Dualoy 3000/LCX
  - (d) **Product to be stored in each tank:** (TK # 5) - Diesel Fuel, (TK # 6, 7, 8) - Gasoline
  - (e) **Type of leak detection being used:**
    - Tank:** (TK # 5, 6, 7, 8) - (Installing) Interstitial Monitoring Veeder Root TLS 350
    - Piping:** (TK # 5) - (Installing) Mechanical Pressurized Line Leak Detection Red Jacket FX1D , (TK # 5, 6, 7, 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all dispenser sumps and all submersible sumps, (TK # 6, 7, 8) - (Installing) Mechanical Pressurized Line Leak Detection Red Jacket FX1
  - (f) **Corrosion Protection being used:**
    - Tank:**
    - Piping:**
  - (g) **Spill containment devices:** (TK # 5, 6, 7, 8) - (Installing) Manhole Pre-manufactured OPW 1-2100
  - (h) **Overfill prevention devices:** (TK # 5, 6, 7, 8) - (Installing) Ball Float Vent Valve OPW 53 , (TK # 5, 6, 7, 8) - (Installing) Overfill Alarm Veeder Root TLS 350
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Contact Person: Phone: (815) 398-6250  Contractor Registration # IL-1890 Exp. 03/07/2010
--

Sincerely,



cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)