



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 5-020728
Permit # 00188-2013UPG
Request Rec'd 03/12/2013
Amended Date
Approval Date 3/13/2013 DS
Permit Expires 9/13/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Thornton's, Inc. 10101 Linn Station Road, P.O. Box 34230 Louisville, KY 40223 Contact: Patty Leonhardt (800) 928-8022	(2) FACILITY - name and address where tanks are located: Thorntons #369 2903 Woodlawn Road Lincoln, Logan Co., IL Contact: Bryan Ritter (217) 735-3915
---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 13, 14, 15, 16, 17) - 12,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 13, 14, 15, 16, 17) - (Installing) Dispenser Sumps containment FRP, (TK # 13, 14, 15, 16, 17) - (Installing) Submersible Sumps containment FRP, (TK # 13, 14, 15, 16, 17) - (Installing) Fiberglass Single Wall Vent Piping Ameron, (TK # 13, 14, 15, 16, 17) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX product piping from tanks to new dispensers

(d) *Product to be stored in each tank:* (TK # 13, 14, 15, 16, 17) - Gasoline

(e) *Type of leak detection being used:*

Tank: (TK # 13, 14, 15, 16, 17) - (EXISTING) Automatic Tank Gauging Veeder Root TLS 350

Piping: (TK # 13, 14, 15, 16, 17) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350, (TK # 13, 14, 15, 16, 17) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all dispenser and submersible sumps

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 13, 14, 15, 16, 17) - (Installing) Fiberglass Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 13, 14, 15, 16, 17) - (Installing) Manhole Pre-manufactured EBW 705

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Oreana, IL 62554	Contact Person: Chuck Hoenig Phone: (217) 468-2393 Contractor Registration # Exp.
-----------------------------------------------------------------------------	---------------------------------------------------------------------------------------------

Sincerely,

Daniel Starks

