



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

**Amended**

<b>FOR OFFICE USE ONLY</b> Facility # 7-011747 Permit # 00039-2013INS Request Rec'd 01/16/2013 Amended Date 03/07/2013 Approval Date 1/23/2013 DS Permit Expires 7/23/2013
--

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>2James, LLC          5850 Hwy 145          Harrisburg, IL 62946          Contact: James Still</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Mitchellville Country Store          5850 Highway 145 South          Harrisburg, Saline Co., IL          Contact: James Still</p>
---	---

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:* (TK # 8) - 30,000 gallons
- (b) Type of tanks:* (TK # 8) - (Installing) Composite Double Wall Glasteel II
- (c) Type of piping:* (TK # 8) - (Installing) Dispenser Sumps containment FRP, (TK # 8) - (Installing) Submersible Sumps containment FRP, (TK # 8) - (Installing) Flexible Double Wall A.P.T. Poly Tech P200SC
- (d) Product to be stored in each tank:* (TK # 8) - Diesel Fuel
- (e) Type of leak detection being used:*  
  - Tank:** (TK # 8) - (Installing) Automatic Tank Gauging Incon TS 1001 , (TK # 8) - (Installing) Interstitial Monitoring Incon TS 1001
  - Piping:** (TK # 8) - (Installing) Electronic Pressurized Line Leak Detection Incon TS LLD , (TK # 8) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TS 1001 in all dispenser and submersible sumps
- (f) Corrosion Protection being used:*  
  - Tank:** (TK # 8) - (Installing) Composite Non-Corrosive
  - Piping:** (TK # 8) - (Installing) Flexible Non-Corrosive
- (g) Spill containment devices, piping and dispenser containment devices:* (TK # 8) - (Installing) Manhole Pre-manufactured OPW 1-2100
- (h) Overfill prevention devices:*

**(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

**(6) SPECIAL CONTINGENCIES:**

<p><b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b></p>	<p>Contact Person: Robert Ellis          Phone: (618) 684-6026          Contractor Registration # IL-980 Exp.</p>
---	---

Sincerely,

Daniel H. Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 9/10)