

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

#### **Division of Technical Services**

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

#### Extended

FOR OFFICE USE ONLY

Facility # 2-019445 Permit # 01225-2008INS Request Rec'd 07/24/2008 Amended Date Approval Date 7/24/2008 JC

Approval Date 7/24/2008 J Permit Expires 7/24/2009

# Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Edward Hines Jr. Hospital 5th & Roosevelt Rd., Hines, IL 60140	Edward Hones Jr. Hospital 5th & Roosevelt Rd Hines, Cook Co., IL
Contact: Larry Koneicki (708) 202-2387 Ext.	Contact: Larry Koneicke (708) 202-2387

## (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 25) 3,000 gallons
- (b) Type of tanks: (TK # 25) (Installing) Fiberglass Double Wall Containment Solutions
- (c) Type of piping: (TK # 25) (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX
- (d) Product to be stored in each tank: (TK # 25) Diesel Fuel
- (e) Type of leak detection being used:

*Tank:* (TK # 25) - (Installing) Automatic Tank Gauging Veeder Root TLS 300c , (TK # 25) - (Installing) Interstitial Monitoring Veeder Root TLS 300c

*Piping:* (TK # 25) - (Installing) European with No Test Req Suction, (TK # 25) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 300c

(f) Corrosion Protection being used:

 $\textit{Tank:} \ (TK \# 25)$  - (Installing) Fiberglass Non-Corrosive

Piping: (TK # 25) - (Installing) Fiberglass Non-Corrosive

- (g) Spill containment devices: (TK # 25) (Installing) Manhole Pre-manufactured OPW 1-2100
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

(	(7)	PERSON.	FIRM OR	COMPANY	PERFORM	ING WORK

Contact Person:

Daniel J. Starke

Phone: (815) 923-4510

Contractor Registration # IL-1943 Exp. 04/26/2010

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department Office Coordinator Division File

(Rev. - 1/98)