



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2000995
Permit # 01532-2016UPG
Request Rec'd 12/02/2016
Amended Date
Approval Date 12/5/2016 DS
Permit Expires 6/6/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Ozinga Bros., Inc, 19001 Old LaGrange Road Mokena, IL 60448 Contact: Richard Slager (312) 656-8393	(2) FACILITY - name and address where tanks are located: Ozinga Bros., Inc. 200 West Jarvis Avenue Des Plaines, IL 600181952 Contact: Richard Slager (312) 656-8393
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 11) - 10,000, (TK # 12) - 20,000**
- (b) Type of tanks:**

(c) Type of piping: (TK # 11, 12) Piping - Fiberglass Single Wall Piping Ameron 4000 L single wall vent, (TK # 11, 12) Piping - Flex Connector Steel
- (d) Product to be stored in each tank: (TK # 11) - Dyed Diesel, (TK # 12) - Diesel Fuel**
- (e) Type of leak detection being used:**

Tank:

Piping:
- (f) Corrosion Protection being used:**

Tank:

Piping:
- (g) Spill containment devices, piping, and dispenser containment devices:**
- (h) Overfill prevention devices:**
- (i) Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : Vents will be re-routed after canopy is removed

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Superior Petroleum Marketers, Inc. 2336 Albright Lane P. O.Box 4648 Wheaton, IL 601894648	Contact Person: Steve Tuttle Phone: (630) 588-1198 Contractor Registration # IL2087 Exp. 2/4/2018
--	---

Sincerely,

Daniel S. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File