



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 5006067
Permit # 01547-2016UPG
Request Rec'd 12/07/2016
Amended Date
Approval Date 12/12/2016 DS
Permit Expires 6/13/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Girm &amp; Sidhu Corporation 986 Honeysuckle Drive Wheeling IL 60090  Contact: BJ Sidhu (630) 862-0941</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>T-Mart BP 517 East 4th Street Beardstown, IL 62618  Contact: Rocky Bhalla (217) 323-5829</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6) Piping - Fiberglass Single Wall Piping A.O. Smith*
- (d) Product to be stored in each tank: (TK # 6) - Gasoline*
- (e) Type of leak detection being used:*  
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*  
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : We are cutting out flawed spot on piping that is contained within tank sump, and installing fiberglass coupling for 3" section that is being removed. NOTE: If there is not a sump where piping is being broken one must be installed per 175.410 b)

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>WJ Scott Company 3861 Tozer Road Springfield, IL 62707</p>	<p>Contact Person: James Scott Phone: (217) 787-6081 Contractor Registration # IL1949 Exp. 4/18/2018</p>

Sincerely,



---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File