



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3029899
Permit # 01552-2016UPG
Request Rec'd 12/09/2016
Amended Date
Approval Date 12/12/2016 DS
Permit Expires 12/23/2016

Permit for Emergency Repair Request on 12/9/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>City of Galesburg 55 West Tompkins Galesburg IL 61401</p> <p>Contact: David Jones (309) 345-3629</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>City Garage 68 S Arthur Ave Galesburg IL 61401</p> <p>Contact: Myron Miller (309) 345-3678</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 5) - 10,000

(b) Type of tanks:

(c) Type of piping: (TK # 5) Piping - Other Steel Riser

(d) Product to be stored in each tank: (TK # 5) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : We are currently on site for spill bucket replacement, being done under like for like. The Unleaded fill riser appears to have been threaded to deeply into 4" tank bung, will not come out and there is a noticeable small crack on top of the frp tank directly outside of the 4" bung. we have stopped any attempts to remove the riser for fear of compromising the tank. The City has hired the tank manufacturer to replace the bung and make any needed repair directly out side of the bung and test the repairs. Once complete we can finish the spill bucket replacement and schedule our hydro tests.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360


Contact Person: Chuck Hoening

Des Moines, IA 50313

Phone: (816) 761-1270

Contractor Registration # IL598 Exp. 2/23/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File