



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2016489
Permit # 01556-2016UPG
Request Rec'd 12/11/2016
Amended Date
Approval Date 12/12/2016 DS
Permit Expires 6/13/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Sam Funteas 815 East Greenview Rd Itasca, IL 60143 Contact: Sam Funteas (630) 935-0470</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Genesis 337 W. Irving Park Rd. Wood Dale, IL 60191 Contact: Nancy Funteas (630) 935-0470</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:


- (a) Number and size of tanks being upgraded or repaired: (TK # 8) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 8) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC*
- (d) Product to be stored in each tank: (TK # 8) - Diesel Fuel*
- (e) Type of leak detection being used:*
Tank:
Piping: (TK # 8) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replacing existing Environ double wall flexible pipe from existing diesel submersible sump to existing island sump with new APT double wall flexible pipe. Existing Environ pipe has bad fitting in sump under the dispenser and is obsolete. We will also be installing a Veeder Root sump sensor in the dispenser sump. The new dispenser sump sensor, and the existing submersible sensor will be wired to the TLS 350 ATG and will shut down submersible if sensor is tripped. New line will be precision tested prior to use.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>U.S. Venture, Inc. 425 Better Way Appleton, WI 54915</p>	<p>Contact Person: Terry Jandrey Phone: (920) 735-8249 Contractor Registration # IL002403 Exp. 3/31/2018</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File