



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453152

FOR OFFICE USE ONLY

Facility # 2006895
Permit # 01599-2016UPG
Request Rec'd 12/22/2016
Amended Date
Approval Date 12/22/2016
Permit Expires 6/22/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Ryder Truck Rental, Inc. 16155 Park Row, Suite 140 Houston, TX 77084 Contact: Jason Blackburn (281) 647-8900	(2) <u>FACILITY</u> - name and address where tanks are located: Ryder Transportation Serv #0323A 1050 W Pershing Rd Chicago, IL 60609 Contact: David Bruckman 773523555
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 8) - 15,000, (TK # 9) - 10,000, (TK # 10) - 6,000, (TK # 11) - 4,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 8) - Diesel Fuel, (TK # 9) - Gasoline, (TK # 10) - New Oil, (TK # 11) - Used Oil*

(e) *Type of leak detection being used:*

Tank: (TK # 8, 9, 10, 11) Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 with SCALD

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Ray Kirchner
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2018

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File