



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2024605
Permit # 00009-2017UPG
Request Rec'd 12/23/2016
Amended Date
Approval Date 1/3/2017 DS
Permit Expires 7/5/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Schaumburg School District #54 524 East Schaumburg Road Schaumburg IL 60194</p> <p>Contact: Mike Mostacci (847) 357-6855</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Schaumburg School District 524 East Schaumburg Road Schaumburg IL 60194</p> <p>Contact: Mike Mostacci (847) 357-6855</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Fiberglass Double Wall , (TK # 2) Piping - Dispenser Sumps OPW DS-1000 Series , (TK # 2) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline*
- (e) Type of leak detection being used:*
Tank:
Piping: (TK # 2) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Franklin Fueling Systems DC 400
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Installing dispenser sump at existing dispenser location to facilitate impact valve mounting and elevation correction. This is only dispenser associated with tank and a Franklin Fueling Dispenser "Cut-Off" sensor will be installed.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Interstate Pump & Tank, Inc. 901 Niagara Street Waukesha, WI 53186	Contact Person: Dan McMahon Phone: (262) 524-8494 Contractor Registration # IL1171 Exp. 5/7/2018

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File