



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6000527
Permit # 00017-2017UPG
Request Rec'd 01/04/2017
Amended Date
Approval Date 1/4/2017 DS
Permit Expires 7/5/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: USAF Air Mobility Command 375th CES/CEV 701 Hangar Road Scott AFB, IL 62225 Contact: Carla Daggitt (618) 256-4165	(2) <u>FACILITY</u> - name and address where tanks are located: Scott AFB - Building 1575 375th CES/CEV 701 Hangar Road Scott AFB, IL 62225 Contact: Christopher Carlisle (618) 256-2092
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 104, 105, 106, 107) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 104, 105, 106, 107) - Gasoline*

(e) *Type of leak detection being used:*

Tank: (TK # 104, 105, 106, 107) Leak Detect - Tank - Monthly Inv Ctrl and Prec Tight Testing , (TK # 104, 105, 106, 107) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus , (TK # 104, 105, 106, 107) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450 Plus

Piping: (TK # 104, 105, 106, 107) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus , (TK # 104, 105, 106, 107) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Installation of new ATG Veeder Root TLS-450 with tank and piping sensors.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
Saint Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501

Sincerely,



Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File