



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 4012377
Permit # 00028-2017UPG
Request Rec'd 01/05/2017
Amended Date
Approval Date 1/5/2017 DS
Permit Expires 7/6/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>CP Tanks, LLC 811 W. Springfield Ave., Ste 201 Champaign, IL 61820 Contact: Chad Fluck (317) 381-5122</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Village Pantry #1210 SE Corner I-74 &amp; Collision Rd Oakwood, IL 61858 Contact: Emily Keltner (910) 796-2436</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 10,000, (TK # 8) - 14,000, (TK # 9) - 4,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 6, 7) - Diesel Fuel, (TK # 8, 9) - Gasoline*

(e) *Type of leak detection being used:*

*Tank: (TK # 6, 7, 8, 9) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : replace tank monitor with new Veeder Root TLS 450

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>K &amp; W Fueling Systems, Inc. 1537 South 275 West PO Box 116 Rushville, IN 46173</p>	<p>Contact Person: Gregg Koors Phone: (765) 932-4980 Contractor Registration # IL002380 Exp. 9/28/2017</p>

Sincerely,

*Daniel G. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File