



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

<p align="center"><b>FOR OFFICE USE ONLY</b></p> <p>Facility # 4012377 Permit # 00028-2017UPG Request Rec'd 01/05/2017 Amended Date 01/11/2017 Approval Date 1/5/2017 DS Permit Expires 7/6/2017</p>
--

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>CP Tanks, LLC 811 W. Springfield Ave., Ste 201 Champaign, IL 61820  Contact: Chad Fluck (317) 381-5122</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Village Pantry #1210 SE Corner I-74 &amp; Collision Rd Oakwood, IL 61858  Contact: Emily Keltner (910) 796-2436</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 10,000, (TK # 8) - 14,000, (TK # 9) - 4,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 6, 7) - Diesel Fuel, (TK # 8, 9) - Gasoline*
- (e) Type of leak detection being used:*
  - Tank: (TK # 6, 7, 8, 9) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD*
  - Piping: (TK # 6) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus, (TK # 6) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

adding Probes ,sump sensors,PLLD,s

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

K & W Fueling Systems, Inc.  
1537 South 275 West PO Box 116  
Rushville, IN 46173

Contact Person: Gregg Koors  
Phone: (765) 932-4980  
Contractor Registration # IL002380 Exp. 9/28/2017

Sincerely,

*Daniel H. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File