



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5027648
Permit # 00099-2017UPG
Request Rec'd 01/25/2017
Amended Date
Approval Date 1/25/2017 DS
Permit Expires 7/25/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Avenue Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238	(2) <u>FACILITY</u> - name and address where tanks are located: Casey's General Store #2939 3001 East Clear Lake Avenue Springfield, IL 62702 Contact: JillReams Widder (515) 965-6238
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5, 6, 7) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 5, 6, 7) Piping - Shear Valves, (TK # 5, 6, 7) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series, (TK # 5, 6, 7) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 5, 6, 7) - Gasoline*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Under Dispenser # 5/6, # 9/10, # 19/20, # 21/22 containment dosen't exist. Installing New 4' x 11' islands with Apt poly dispenser sumps, steel flex connectors, OPW 10P-0152 sheer valve & partial single wall Ameron fiberglass piping into the new sumps (less than 20' per run)

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360


Contact Person: Chuck Hoening

Des Moines, IA 50313

Phone: (816) 761-1270

Contractor Registration # IL598 Exp. 2/23/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File