



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2046309
Permit # 01537-2016INS
Request Rec'd 12/02/2016
Amended Date 03/07/2017
Approval Date 12/5/2016 DS
Permit Expires 6/6/2017

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Murphy Oil USA, Inc. 200 East Peach Street El Dorado, AR 71730 Contact: Harry Lewis (870) 875-7600	(2) <u>FACILITY</u> - name and address where tanks are located: Murphy Express 16030 S. Farrell Road Lockport, IL 60441 Contact: Brad Weinischke (870) 875-7610
--	---

(3) INSTALLATION OF TANKS:

(a) Number and size of tanks being installed: (TK # 4) - 8,000

(b) Type of tank(s): (TK # 4) Tank - Fiberglass Double Wall

(c) Type of piping: (TK # 4) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 4) Piping - Submersible Sumps Franklin Fueling Systems A-4200 Series, (TK # 4) Piping - Dispenser Sumps Bravo B-1000 Series

(d) Product to be stored in each tank: (TK # 4) - E-85

(e) Type of leak detection being used:

Tank: (TK # 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus, (TK # 4) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450 Plus

Piping: (TK # 4) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D, (TK # 4) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus

(f) Corrosion Protection being used:

Tank: (TK # 4) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 4) Corrosion Prot - Piping - Fiberglass Non-Corrosive

(g) Spill containment devices, piping and dispenser containment devices: (TK # 4) Spill Contain Device - Pre-manufactured Emco Wheaton EBW 705 Defender II

(h) Overfill prevention devices: (TK # 4) Overfill Prev Device - Overfill Alarm Veeder Root TLS 450plus

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(5) GENERAL REQUIREMENTS : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) **SPECIAL CONTINGENCIES :**


Piping correction and tank containing E-85 will not contain E-0.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Harco Services, LLC
3271 Old Highway 41
Kennesaw, GA 30144

Contact Person: Jerry Hollis
Phone: (770) 917-8846
Contractor Registration # IL002286 Exp. 9/5/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File