



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3010676
Permit # 00344-2017UPG
Request Rec'd 03/23/2017
Amended Date
Approval Date 3/27/2017 DS
Permit Expires 9/27/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>US Government Rock Island Arsenal/IMRI-PWE Rock Island, IL 61299 Contact: Reita Kuster (309) 782-7855</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Rock Island Arsenal Rock Island Arsenal Rock Island, IL 61299 Contact: Reita Kuster (309) 782-7855</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 43) - 20,000, (TK # 44) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 43, 44) Piping - Fiberglass Double Wall A.O. Smith, (TK # 43, 44) Piping - Dispenser Sumps Franklin Fueling Systems 3600 Series*

(d) *Product to be stored in each tank: (TK # 43) - Gasoline, (TK # 44) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 43, 44) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Incon TSP ULS

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

partial repipe in island excavated area only to allow for new dispenser sump installation with new island sump sensors.

Sensors to be incon #tsp-uls.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illowa Enterprises, Inc.
2703 4th Avenue


Contact Person: Rob Vynck

Moline, IL 61265

Phone: (309) 762-1729

Contractor Registration # IL981 Exp. 5/1/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File