



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 6034411
Permit # 00186-2017UPG
Request Rec'd 02/15/2017
Amended Date 04/03/2017
Approval Date 2/21/2017 DS
Permit Expires 8/22/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main St. P.O. Box 0122 Belleville, IL 622220122 Contact: Rob Whittington (618) 233-6754 Ext. 106	(2) <u>FACILITY</u> - name and address where tanks are located: Club Centre Moto Mart #1 Club Centre Court Edwardsville, IL 62025 Contact: Jim Warnecke (618) 233-6754
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 20,000, (TK # 3) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2, 3) Piping - Fiberglass Double Wall , (TK # 2, 3) Piping - Valves Ball Valve, (TK # 2, 3) Piping - Submersible Sumps Franklin Fueling Systems A-4200 Series , (TK # 2, 3) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline, (TK # 3) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Customer wants to add changing the diesel sump at the same time.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
1458 Collins Street
St. Louis, MO 63102

Contact Person: Harvey Stokes
Phone: (314) 241-3767
Contractor Registration # IL002402 Exp. 2/10/2018

Sincerely,

Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File