



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 2005558
 Permit # 00393-2017CAT
 Request Rec'd 04/05/2017
 Amended Date
 Approval Date 4/5/2017 DS
 Permit Expires 10/5/2017

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>2401, Inc. & OFGD, Inc. 2401 W. Lincoln Hwy. Olympia Fields, IL 60461</p> <p>Contact: George Nedyakalayil (847) 910-1068</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>2401 Inc & OFGD Inc 2401 W. Lincoln Hwyj. Olympia Fields, IL 60461</p> <p>Contact: George Nedyakalayil (847) 910-1068</p>
--	---

(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 6) - 10,000, (TK # 7) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 6, 7) - Gasoline*
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping: (TK # 6, 7) Corrosion Prot - Piping - Sacrificial Anode Flex Connector spike anode
- (g) *NACE certified designer:*
- (h) *Method of integrity assessment of tank(s) being used:*

(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling 2177851020.

(5) **SPECIAL CONTINGENCIES** : Replace 9LB anodes on the Flex Connectors

(6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

<p>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Protanic, Inc. 658 North Progress Drive PO Box 80265 Saukville, WI 53080</p>	<p>Contact Person: Frank Grebas Phone: (262) 268-1150 Contractor Registration # IL1413 Exp. 8/29/2018</p>

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File