



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4034450
Permit # 00412-2017UPG
Request Rec'd 04/11/2017
Amended Date
Approval Date 4/11/2017 DS
Permit Expires 10/11/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Martin & Bayley, Inc. PO Box 385 Carmi, IL 62821 Contact: Troy Dietz (618) 382-2334 Ext. 248</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Hucks #287 204 North 22nd Street Decatur, IL 62721 Contact: Sherri Rice (217) 423-6410</p>
--	--

(3) **UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000, (TK # 2, 3) - 10,000, (TK # 4) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3, 4) Piping - Flexible Double Wall OPW Pisces, (TK # 1, 2, 3, 4) Piping - Shear Valves, (TK # 1, 2, 3, 4) Piping - Valves Ball Valve, (TK # 1, 2, 3, 4) Piping - Submersible Sumps OPW Flexworks Poly Sump, (TK # 1, 2, 3, 4) Piping - Flex Connector Steel, (TK # 4) Piping - Galvanized Steel Single Wall Piping*
- (d) *Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1, 2, 3, 4) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 4) Spill Contain Device - Manhole Pre-manufactured OPW 1-2100*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Replacing tank top sumps with new ones across all tanks. Diesel tank gets new fill riser and spill container. Running new flexible piping inside of existing chase pipe to all dispensers from each tank. Installing new ball valves, flex connectors, and shear valves. Installing new sumps sensors at dispenser sumps, existing sumps sensor for tank top sumps will be reinstalled. Demolition existing islands and installing islandless islands in their place.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.
5060 Arsenal Street
Saint Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2018

Sincerely,



Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File