



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2022908
Permit # 00420-2017ABN
Request Rec'd 11/21/2016
Amended Date
Approval Date 4/13/2017 DS
Permit Expires 10/13/2017

Permit for ABANDONMENT IN PLACE of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Graham C-Stores Co. 33978 N. US Hwy 45 Gages Lake, IL 600300089 Contact: John Graham (847) 937-0777	(2) <u>FACILITY</u> - name and address where tanks are located: Elmhurst BP 1003 N. York Road Elmhurst, IL 60126 Contact: Linda Horstman (630) 833-2213
---	---

(3) **ABANDONMENT IN PLACE OF PIPING:**

(a) *Location of piping being abandoned:*

(b) *Which tank(s) are associated with the piping being removed: (TK # 12) - 10,000*

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES :**

Environ pipe is kinked going into dispenser 11 & 12 center product line. this has over time caused the piping inside the sump to leak.

Removal of this line is not possible as it is not located in a 4" chase.

(6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(7) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Ray Kirchner
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2018

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File