



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 7011747
 Permit # 00461-2017UPG
 Request Rec'd 04/24/2017
 Amended Date
 Approval Date 4/24/2017 DS
 Permit Expires 5/5/2017

Permit for Emergency Repair Request on 4/24/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>2 James, LLC 5850 Hwy 145 Harrisburg IL 62946 Contact: Mike Duncan (618) 694-9060</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Mitchellville Country Store 5850 Highway 145 South Harrisburg IL 62946 Contact: Mike Duncan (618) 252-6414</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 7) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 7) Piping - Shear Valves*
- (d) *Product to be stored in each tank: (TK # 7) - Gasoline*
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replacing a bad sheer valve under dispenser # 4 with a OPW 10BFP-5726 double poppet sheer valve. We will preform a passing line test & functionality test on trhe valve before putting back into service. **NOTE: If there is not an existing dispenser sump where piping is being broken, one must be installed under a SEPARATE uprade permit.**

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313</p>	<p>Contact Person: Chuck Hoening Phone: (816) 761-1270 Contractor Registration # IL598 Exp. 2/23/2018</p>

Sincerely,

Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File