



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1011001
Permit # 00489-2017INS
Request Rec'd 04/24/2017
Amended Date
Approval Date 5/1/2017 DS
Permit Expires 11/1/2017

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Illinois State Toll Highway Authority 2700 Ogden Avenue Downers Grove, IL 60515 Contact: Tom Deldin (630) 241-6800 Ext. 3919	(2) <u>FACILITY</u> - name and address where tanks are located: ISTHA M07 Maint. Garage Business 20 & I-90 Northwest Tollway, Mile Post 63.5 Rockford, IL 61108 Contact: Kelly Olesen (815) 399-2882
--	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 8, 10) - 10,000, (TK # 9) - 12,000*
 - (b) Type of tank(s): (TK # 8, 9, 10) Tank - Fiberglass Double Wall XERXES*
 - (c) Type of piping: (TK # 8, 9, 10) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L, (TK # 8, 9, 10) Piping - Other fiberglass riser, (TK # 8, 9, 10) Piping - Other submersible pump, (TK # 8, 9, 10) Piping - Fiberglass Secondary Containment Ameron, (TK # 8, 9, 10) Piping - Extractor Fitting Valves, (TK # 8, 9, 10) Piping - Positive Shutoff Valves, (TK # 8, 9, 10) Piping - Shear Valves, (TK # 8, 9, 10) Piping - Valves Ball Valve, (TK # 8, 9, 10) Piping - Dispenser Sumps Bravo B-7000 Series, (TK # 8, 9, 10) Piping - Submersible Sumps Bravo B-400 Series, (TK # 8, 9, 10) Piping - Flex Connector Steel*
 - (d) Product to be stored in each tank: (TK # 8) - E-85, (TK # 9) - Diesel Fuel, (TK # 10) - Gasoline*
 - (e) Type of leak detection being used:*
 - Tank: (TK # 8, 9, 10) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD, (TK # 8, 9, 10) Leak Detect - Tank - Hydrostatic Reservoir Sensors Interstitial Monitoring Veeder Root TLS 450 interstitial brine sensor, (TK # 8, 9, 10) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450 Plus*
 - Piping: (TK # 8, 9, 10) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus, (TK # 8, 9, 10) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus*
 - (f) Corrosion Protection being used:*
 - Tank: (TK # 8, 9, 10) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
 - Piping: (TK # 8, 9, 10) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
 - (g) Spill containment devices, piping and dispenser containment devices: (TK # 8, 9, 10) Spill Contain Device - Manhole Pre-manufactured OPW 1-2100-DEVR, (TK # 8, 9, 10) Spill Contain Device - Manhole Pre-manufactured Universal 62*
 - (h) Overfill prevention devices: (TK # 8, 9, 10) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube*
- (4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All

steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.


- (6) **SPECIAL CONTINGENCIES** : Please verify on the notification form exactly which spill containment is being installed as more than one are listed.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Ceroni Piping Company
1372 Ipsen Road
Belvidere, IL 61008

Contact Person: Steve Ceroni
Phone: (815) 332-7777
Contractor Registration # IL2147 Exp. 6/25/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File