



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 7042092  
Permit # 00569-2017UPG  
Request Rec'd 05/18/2017  
Amended Date  
Approval Date 5/18/2017 DS  
Permit Expires 11/20/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|                                                                                                                                                                                                                                                  |                                                                                                                                                                                                |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Love's Travel Stops &amp; Country Stores, Inc.<br/>P.O. Box 26210<br/>Oklahoma City, OK 73120<br/><br/>Contact: Kyle Collins (405) 834-0311</p> | <p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Love's Travel Stop #318<br/>202 North Avenue<br/>Ina, IL 62846<br/><br/>Contact: Mike Katz (405) 302-6640</p> |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000*

*(b) Type of tanks:*

*(c) Type of piping: (TK # 1) Piping - Shear Valves*

*(d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*

*(e) Type of leak detection being used:*

*Tank:*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containment devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES** : Replacing shear valve with new OPW 10RUP2006 shear valve. NOTE: If there is no dispenser sump where shear valve is being replaced one must be installed per 175.410 d)

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
Saint Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2018

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File