



**City of Chicago
Department of Public Health**
333 South State Street, Room 200
Chicago, IL 60604
3127453152

FOR OFFICE USE ONLY

Facility # 2021796
Permit # 00622-2017REM
Request Rec'd 05/31/2017
Amended Date
Approval Date 6/1/2017
Permit Expires 12/1/2017

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:

Chicago Park District
541 North Fairbanks Court
Chicago, IL 60611

Contact: Dan Cooper (312) 742-4287

(2) FACILITY - name and address where tanks are located:

Northerly Island - Maintenance Building
1521 South Linn White Drive
Chicago, IL 60605

Contact: Daniel Cooper (312) 747-7695

(3) REMOVAL OF PIPING:

(a) Description/location of piping being removed:

(b) Which tank(s) are associated with the piping being removed: (TK # 2) - 2,000

(c) Reason of piping being removed:

(d) If piping is leaking, indicate IEMA incident number: 2015-0192

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.


(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

SET Environmental, Inc.
450 Sumac Road
Wheeling, IL 60181

Contact Person: Mike Lanenga
Phone: (847) 850-1075
Contractor Registration # IL1924 Exp. 3/7/2019

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File