



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2006853  
Permit # 00633-2017UPG  
Request Rec'd 06/04/2017  
Amended Date  
Approval Date 6/5/2017 DS  
Permit Expires 12/5/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Mair, Inc. 1 East St. Charles Road Lombard, IL 60148  Contact: Mohammad (630) 629-8832</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>St. Sebastian Oil Group, Inc. 1 East St. Charles Road Lombard, IL 60148  Contact: Nidhin Joseph (630) 785-3633</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 1, 2, 3) Piping - Dispenser Sumps NUPI HDPE*
- (d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 1, 2, 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXI*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping: (TK # 1, 2, 3) Corrosion Prot - Piping - Sacrificial Anode Flex Connector spike anode*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3) Spill Contain Device - Manhole Pre-manufactured EBW 705*
- (h) Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SO*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Removing the (3) existing dispensers, breaking out / removing the (3) existing concrete dispenser islands (w/ steel forms), installing (1) new Nupi dispenser sump, revising the existing SWFRP piping to facilitate the installation of new sump, and installing (3) new Wayne Ovation dispensers. All existing tanks, other dispenser sumps, spill / overfill, leak detection and cathodic protection are to remain.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Tim Berg

Performance Tank, Inc.  
730 Creel Drive  
Wood Dale, IL 60191

Phone: (630) 860-9500  
Contractor Registration # IL881 Exp. 10/27/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File