



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2046326  
Permit # 00657-2017ABN  
Request Rec'd 06/08/2017  
Amended Date  
Approval Date 6/8/2017 DS  
Permit Expires 12/8/2017

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Makand Property 46 Tanglewood Dr. Glen Ellyn, IL 60137</p> <p>Contact: Richard Andros (630) 790-0778</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Blueberry Hill Breakfast Cafe 49 S. La Grange Rd. La Grange, IL 60525</p> <p>Contact: Richard Andros (708) 352-4900</p>
---	--

(3) **ABANDONMENT IN PLACE OF TANKS:**

- (a) *Number and size tanks being abandoned: (TK # 2, 3) - 500*
- (b) *Product stored in each tank: (TK # 2, 3) - Heating Oil*
- (c) *Location of tanks being abandoned: Tanks are located in close proximity of an existing building as shown in site plan. Attempting to remove the tanks would likely undermine the structural integrity of the building.*
- (d) *Location of piping being abandoned: Piping is located in close proximity of an existing building as shown in site plan. Attempting to remove the piping would likely undermine the structural integrity of the building.*

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES :**

- (6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfmillinois.gov](http://www.sfmillinois.gov) or by calling (217)785-1020.

(7) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

RW Collins Company  
7225 West 66th Street  
Chicago, IL 60638

Contact Person: Mike Ziwer  
Phone: (708) 458-6868  
Contractor Registration # IL772 Exp. 2/9/2018

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File