



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453152

**FOR OFFICE USE ONLY**

Facility # 2007794  
Permit # 00678-2017INS  
Request Rec'd 05/15/2017  
Amended Date  
Approval Date 6/13/2017  
Permit Expires 12/13/2017

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|                                                                                                                                                                                                                                          |                                                                                                                                                                                        |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>AT&amp;T Corp. d/b/a Illinois Bell<br/>308 S. Akard, Room 1700<br/>Dallas, TX 75202</p> <p>Contact: Chantel McMorris (800) 566-9347</p> | <p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Monroe CO<br/>1340 West Monroe<br/>Chicago, IL 60607</p> <p>Contact: Lisa Espinosa (312) 226-9953</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**(3) INSTALLATION OF TANKS:**

*(a) Number and size of tanks being installed: (TK # 3) - 8,000*

*(b) Type of tank(s): (TK # 3) Tank - Composite Double Wall ACT 100*

*(c) Type of piping: (TK # 3) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L, (TK # 3) Piping - Extractor Fitting Valves, (TK # 3) Piping - Valves Ball Valve, (TK # 3) Piping - Valves Foot Valve, (TK # 3) Piping - Submersible Sumps OPW Fiberglass, (TK # 3) Piping - Flex Connector Steel*

*(d) Product to be stored in each tank: (TK # 3) - #2 Fuel Oil*

*(e) Type of leak detection being used:*

*Tank: (TK # 3) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 350 Plus*

*Piping: (TK # 3) Leak Detect - Piping - American with Sensors/No Test Suction, (TK # 3) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus*

*(f) Corrosion Protection being used:*

*Tank: (TK # 3) Corrosion Prot - Tank - Composite Non-Corrosive*

*Piping: (TK # 3) Corrosion Prot - Piping - Fiberglass Non-Corrosive*

*(g) Spill containment devices, piping and dispenser containment devices: (TK # 3) Spill Contain Device - Manhole Pre-manufactured OPW 101-2100*

*(h) Overfill prevention devices: (TK # 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71-SO 4010 Overfill drop tube, (TK # 3) Overfill Prev Device - Overfill Alarm Veeder Root TLS 350 Plus*

**(4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) by calling (217)785-1020.

**(5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion

protection.

**(6) SPECIAL CONTINGENCIES :**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

J & D Mechanical Industries, Inc.  
6521 Main Street, Suite A P.O. Box 113  
Union, IL 60180

Contact Person: Cheryl Zielke  
Phone: (815) 923-4510  
Contractor Registration # IL1943 Exp. 4/26/2018

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

**cc:** Storage Tank Safety Specialist  
Division File