



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2036207
Permit # 00685-2017UPG
Request Rec'd 06/08/2017
Amended Date
Approval Date 6/13/2017 DS
Permit Expires 12/13/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>CIMA Developers, LP (formerly known as Angel Associates, LP) 30W180 Butterfield Rd. Warrenville, IL 60555</p> <p>Contact: Dan Soltis (630) 653-1700</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Pride of Lake County 20915 Quentin Road Kildeer, IL 60047</p> <p>Contact: Guy Morgano (630) 668-0141</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 15,000

(b) Type of tanks:

(c) Type of piping: (TK # 1) Piping - Flexible Double Wall A.P.T. Poly Tech P150SC, (TK # 1) Piping - Shear Valves, (TK # 1) Piping - Valves Ball Valve, (TK # 1) Piping - Dispenser Sumps Bravo B-1000 Series, (TK # 1) Piping - Submersible Sumps Bravo B-400 Series

(d) Product to be stored in each tank: (TK # 1) - Diesel Fuel

(e) Type of leak detection being used:

Tank:

Piping: (TK # 1) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXIV, (TK # 1) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1) Spill Contain Device - Manhole Pre-manufactured OPW 101-2100

(h) Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Drop Tube Valve EBW 708 Auto Limiter

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Removing diesel tank top sump, fuel line to (3) diesel only islands and (3) diesel islands.

Will install new diesel tank top fiberglass sump, product line (APT flex), (3) diesel dispenser sumps with shear valves and Veeder Root sump sensors.

Submersible pump will be reused. New mechanical line leak detector will be installed.

New Overspill manhole will be installed. Reuse existing overfill valve.

(3) New diesel islands and crash protection will be installed in place of removed diesel islands.


Tank #5 will have an integrity tests performed on the tank , line and leak detector as part of this project.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd.
651 S. Sutton Road #214
Streamwood, IL 60107

Contact Person: Robert Sumoski
Phone: (630) 497-9009
Contractor Registration # IL002345 Exp. 5/16/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File