



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2006320
Permit # 00698-2017UPG
Request Rec'd 06/14/2017
Amended Date
Approval Date 6/14/2017 DS
Permit Expires 12/14/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Hill Top Gas, Inc. 590 W. Lincoln Hwy. Chicago Heights, IL 60411 Contact: (773) 858-2300	(2) <u>FACILITY</u> - name and address where tanks are located: Hill Top Gas, Inc. 590 West Lincoln Highway Chicago Heights, IL 60411 Contact: Gigi P. Sam (773) 858-2300
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000, (TK # 2, 3) - 8,000, (TK # 4) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3, 4) Piping - Steel Single Wall Piping, (TK # 1, 2, 3, 4) Piping - Dispenser Sumps OPW DP-1000 Series*
- (d) *Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping:*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Installing 4- Dispenser pans under 4- MPD dispensers using existing steel piping will be removing shear valves and adjusting heights of risers entering dispensers pans installing existing shear valves w/ new mounting hardware. This is to address NOV

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance, LLC.
25850 S. Sunset Dr., Unit 2
Monee, IL 60449

Contact Person: Chris Derro
Phone: (708) 452-8620
Contractor Registration # IL002418 Exp. 3/16/2019

Sincerely,

Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File