



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2020667
Permit # 00713-2017UPG
Request Rec'd 06/16/2017
Amended Date
Approval Date 6/19/2017 DS
Permit Expires 12/19/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Muhammad S. Ansari 218 N. Waukegan Road Lake Bluff, IL 60044</p> <p>Contact: Muhammad Ansari (773) 263-5149</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Lake Bluff Petroleum, Inc. 218 N. Waukegan Rd. Lake Bluff, IL 60044</p> <p>Contact: Muhammad Ansari (847) 234-1991</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:


- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 12,000, (TK # 5) - 4,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4, 5) Piping - Shear Valves, (TK # 4, 5) Piping - Dispenser Sumps Bravo B-1000 Series, (TK # 4, 5) Piping - Transition Sumps Bravo B-830 Series, (TK # 4, 5) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 4, 5) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Removing dispensers to install new sumps then reinstalling dispensers - sawcut and bust islands - pouring new islands. Removing teh existing transition sump and replace with new fiberglass sump. Reuse all existing sump sensors

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>U.S. Venture, Inc. 425 Better Way Appleton, WI 54915</p>	<p>Contact Person: Terry Jandrey Phone: (920) 735-8249 Contractor Registration # IL002403 Exp. 3/31/2018</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File