



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2039731
Permit # 00725-2017UPG
Request Rec'd 06/15/2017
Amended Date
Approval Date 6/19/2017 DS
Permit Expires 12/19/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Costco Wholesale Corporation P.O. Box 35005 Licensing / Legal Department Seattle, WA 981243405 Contact: Dennis Bock (206) 313-8100	(2) <u>FACILITY</u> - name and address where tanks are located: Costco Gasoline Facility #388 1901 West 22nd Oak Brook, IL 60521 Contact: Marco Charo (425) 251-6222
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 30,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 2) Piping - Fiberglass Double Wall A.O. Smith*

(d) *Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 2, 3) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, (TK # 1, 2, 3) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 discriminating containment sump, (TK # 1, 2) Leak Detect - Piping - Siphon Bar

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replace existing dispensers with new Gilbarco Encore 700S, installation of dispenser sump sensors, replacement of existing MLLDs with PLLDs, and replacement of siphon line between tank #1 and tank #2


(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Jones Covey Group, Inc.
9595 Lucas Ranch Road #100

Contact Person: Steve Sills
Phone: (909) 730-9185
Contractor Registration # IL002414 Exp. 10/8/2018

Rancho Cucamonga, CA 91730

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File