



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2032549
Permit # 00766-2017UPG
Request Rec'd 06/27/2017
Amended Date
Approval Date 6/27/2017 DS
Permit Expires 12/27/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145  Contact: Rob Porges (440) 808-7368</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Travel Center of America #30 16650 Russell Road Russell, IL 60075  Contact: Ahmad Zaben (847) 395-5580</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 4, 5) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4, 5) Piping - Fiberglass Double Wall A.O. Smith*
- (d) Product to be stored in each tank: (TK # 4, 5) - Diesel Fuel*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping:*
- (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Found damage previously made to the secondary containment within trench during a concrete replacement project. Replacing approximately a 55 foot section of 4 over 3 telescoping smith fiberglass piping. Piping to be installed in the same position as existing- no layout change. **NOTE: Per STSS Adams the N.O.V. pertaining to the ATG lights has been rectified therefore this permit is being issued to repair product piping. 6/27/2017**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Northern Indiana Mechanical, Inc. 3311 E. 15th Avenue Gary, IN 46403	Contact Person: Mike Kiest Phone: (219) 963-7640 Contractor Registration # IL292 Exp. 3/25/2019

Sincerely,

*Daniel G. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File