



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2029979  
Permit # 00769-2017REM  
Request Rec'd 06/28/2017  
Amended Date  
Approval Date 6/28/2017 DS  
Permit Expires 12/28/2017

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>J.A. Frate, Inc. 1202 So. IL Route 31 McHenry, IL 60050  Contact: Chris Rosinski (815) 788-4427</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>J.A. Frate, Inc. 7900 Pyott Road Crystal Lake, IL 60014  Contact: Chris Rosinski (815) 788-4427</p>
--	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1) - 10,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

- (4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) **SPECIAL CONTINGENCIES** : Remove all underground existing product and vent piping

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company  
1111 West Dundee Road  
Wheeling, IL 600903906

Contact Person: Larry Cherner  
Phone: (847) 465-4000  
Contractor Registration # IL102 Exp. 2/7/2018

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File